



“जल संचय-जीवन संचय”

☎-(01382)-222065

कार्यालय सहायक अभियन्ता (नगर), उत्तराखण्ड जल संस्थान

स्टेशन रोड, कोटद्वार (पौड़ी गढ़वाल)

E-mail ID - JalkalKotdwar@gmail.com



पत्रांक 62 /

प्रमाण पत्र

/ 23-24 दि 02/06/2023

मांग पर


प्रमाण पत्र

प्रमाणित किया जाता है कि ज्ञान भारती पब्लिक स्कूल, नजीबाबाद रोड़ शिवालिक नगर, कोटद्वार जिला पौड़ी गढ़वाल को जल संस्थान द्वारा शुद्ध एवं सुचारू पेयजल आपूर्ति की जा रही है जो कि सर्वथा पीने योग्य है।

यह प्रमाण पत्र प्रधानाचार्य ज्ञान भारती पब्लिक स्कूल, नजीबाबाद रोड़ शिवालिक नगर, कोटद्वार (उत्तराखण्ड) के प्रार्थना पत्र दिनांक 20.05.2023 के आधार पर निर्गत किया जा रहा है।

दिनांक:-02.06.2023


Manager/Principal
GYAN BHARTI PUBLIC SCHOOL
Najibabad Road, Kotdwara


सहायक अभियन्ता (नगर)
उत्तराखण्ड जल संस्थान
कोटद्वार



Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Kotdwar

Ph (O): 01382 - 222219, E-mail: ujseekotdwar@gmail.com

Test Report ID: 01/UJS/SLWQTML/2023-24


Dated: 27/05/2023

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Gyan Bharti Public School Kotdwar -246149 (Garhwal) U.K.		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample collected from Gyan Bharti Public School Kotdwar
Reference Sample Identification:	SDWQTML/UJSK-007	Date of Start of Analysis: 25/05/2023	Date of End of Analysis: 27/05/2023
Date and Time of Sample Received: 25/05/23 & 10:00AM	Sample Collected by:	Deepak Negi Sample Asist.U.J.S.Kotdwar	

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	7.67	6.5 to 8.5	No Relaxation	IS 3025 Pt-11: 2017
2.	Total Dissolved Solids (TDS), mg/L	367	500	2000	IS 3025 Pt-16-2017
3.	Turbidity, NTU	0.15	1	5	IS 3025 Pt-10-2017
4.	Total Alkalinity (as CaCO ₃), mg/L	176	200	600	IS 3025 Pt-23: 2019
5.	Total Hardness (as CaCO ₃), mg/L	202	200	600	IS 3025 Pt-21: 2002
6.	Chloride, mg/l	25.99	250	1000	IS 3025 Pt-32 : 2019
7.	Calcium (as Ca), mg/L	64	75	200	IS 3025 Pt-40 : 2019
8.	Magnesium (as Mg), mg/L	10.21	30	100	APHA 23rd Ed.-3500-Mg B: 2017
9.	Colour, Hazen	Less than 05	5	15	IS 3025 Pt-04 : 2021
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2018
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08 : 2012

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.


Chemist


J.E./A.A.E


Manager/Principal
GYAN BHARTI PUBLIC SCHOOL
Najibabad Road, Kotdwara

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.